

**Town of Hanover DPW
Building Operations Group
Open Work Order Report
John Curtis Free Library**

Printed on: 05/19/2013

Page: 1

WO #	Area Description Area Number Description of Problem	Priority Status	Requested Date	Days Aged
5340		Medium Work In Progress	03/17/2013	63
	Rear light damaged 42"Gardco need parts see if any spare light poles or parts in mechanical room or will have to order.			
5486	1st Floor hallway in front of booksale room Entire row of recessed lights is not functioning. custodian tries to replace but they fall from socket or blow out. Time Available: mon-sat	Medium Work In Progress	04/16/2013	33
5487	Parking Lot outside curb Snow plow knocked the curbing off and also broke off one of the spigots in the underground irrigation system. Time Available: anytime	Medium Work In Progress	04/16/2013	33
5572	1st Floor main entrance Main entrance handicapped door is frozen open. Time Available: 7am-5pm	Medium Work In Progress	05/08/2013	11
5582	1st Floor children's room 3 lights that need new ballasts Time Available: 7am-5pm	Medium Work In Progress	05/09/2013	10

End of report: 1 pages